JAWAHARLAL NEHRU UNIVERSITY ENGINEERING DEPARTMENT SCHEDULE OF QUANTITY

F.No.4 (34)/E/Q/2021-22/Engg./7/2

Dated: 27/05/2021

Sealed item rate quotations are invited from Manufacturers/authorized dealers of LLOYD make ACs /Specialized agencies having similar work experience for the work mentioned below, to be received on 04/06/202 at 3:00 pm in R.No.-141 of Admin. Building, JNU and the same shall be opened at 3:30 pm on the same day.

Name of Work: -: Installation and commissioning of 04 NOs LLOYD make Split ACs in Room No-18 of AIRF Building at JNU.

S. No.	Description of Items	Qty.	Unit	Rate (Rs.)	Amount(Rs.)
1					
	Installation, testing and commissioning of 2.0 ton				
	hi-wall split type AC i/c fixing of 4 core PVC				
	insulated PVC sheathed copper wire of 1.5				
	sq.mm., drain pipe and refrigerant copper pipe	4	Each		
	between indoor and outdoor unit up to 5 meters				
	length i/c chasing the wall and making good the				
	same and wrapping the refrigerant piping with				
	PVC adhesive tape as required.				
2	Supply and fixing of additional refrigerant copper				
	pipe between the indoor and outdoor units of the	18	Mtr.		
	Split type AC unit etc and wrapping the				
	refrigerant piping with PVC adhesive tape as				
	required.				
3	Supply and fixing of additional 4 core PVC				
	insulated PVC Sheathed copper wire of 1.5 sq.	20	Mtr.		
	mm between indoor and outdoor unit of Split	20	MII.		
	type AC complete as required.				
4	Supply and fixing of additional 25 mm dia. solid				
	drain pipe on wall with help of PVC clamp for	5	Mtr.		
	Split type AC etc as required.				
5	Supplying, installation, testing & commissioning				
	of Twin AC Controller in sheet metal fabricated				
	powder coated enclosure for 2.0 TR Split ACs in				
	logic only, one AC is operated at a time and equal	2	Each		
	running of each AC is ensured during continuous				
	operation including built in protection	4			
	operation including built in protection against UV, OV & OL for both AC units.				
	Total				
	IOIAI				

Conditions:-

- 1. The quotation for the work shall remain open for a period of 60 days from the date of opening of quotations. The JNU shall, without prejudice to any other right or remedy, be at liberty to blacklist the agency for one year if any agency/firm withdraw his quotation before validity period or makes any modification in the terms and conditions of the quotation which are not acceptable to the department.
- 2. The work shall be carried out as per specifications defined in the NIQ.
- 3. All the taxes shall be deducted as per GOI rule.
- 4. The quotation shall be submitted in the sealed envelope addressing to EXECUTIVE ENGINEER (E) JNU NEW DELHI within the stipulated time mentioned in the NIQ.
- Time allowed for completion of above work shall be 15 Days which shall be reckoned from the date of issue of order to commence the work.
- 6. The firm has to enclose the self attested copies of all relevant documents such as Dealership/experience certificate, PAN number, and GST number etc. along with quotation.
- Payment shall be made after satisfactory completion of work.
- 8. Security deposit @10% of quoted amount shall be recovered from the bill and shall be refunded after warranty period of six month.

Assistant Engineer (E&M)

Executive Engineer (E)